



NOTES:

1. ENCLOSURE SHALL BE NEMA 4 RATED, 16 INCHES DEPTH.
2. ENCLOSURE SHALL BE CONSTRUCTED OF 14 GA. COLD ROLLED STEEL. UNIT SHALL BE INSULATED WITH 1 INCH RIGID FIBERGLASS, FOIL-BACKED, BOTH SIDES.
3. ENCLOSURE PAINT SHALL BE ASA 61 GREY. TWO COATS BAKED ENAMEL APPLIED OVER ZINC RICH PRIMER.
4. NAMEPLATE #1 SHALL BE 3" X 5" AND SHALL DEPICT THE TANK NUMBER AS ISSUED BY THE DOW.
5. ENCLOSURE SHALL BE SUPPLIED BY HOFFMAN ENGINEERING CO.
6. REFER TO L-8701C FOR ITEM IDENTIFICATION.

REV. 2000

<p>CITY OF COLUMBUS, OHIO DEPARTMENT OF PUBLIC UTILITIES DIVISION OF WATER</p> <p>APPROVED <i>RC Winters</i> ADMINISTRATOR</p> <p>1-21-05 DATE</p>	<p>STANDARD DETAIL TANK INSTRUMENT PANEL ENCLOSURE</p>	<p>L-8701A</p>
------------------------------------------------------------------------------------------------------------------------------------------------------------------------	----------------------------------------------------------------	----------------